

CERTIFICATE

Z 5.1 / 09 – 444 - 4

for
AquaproofX® 1

*joint sheet fully coated on one side with
UV-crosslinked polymer for sealing of working joints and
dummy joint cross sections against pressing and non-pressing water*

Manufacturer:

StekoX GmbH Abdichtungstechnik
Markgröninger Strasse 55/1
71701 Schwieberdingen, Germany

Based on:

Test reports no.:
P 2.2 / 07 - 040/2 of 27 July 2007
P 5.1 / 08 - 220/2 of 10 December 2008
P 5.1 / 08 - 219 of 26 January 2009
by MFPA Leipzig GmbH


Recorded performance characteristics:

- Adhesive strength of coating on joint sheet
- Adhesive strength of coating on concrete
- Operational capability in integrated state
- Impermeability at a continuous water pressure of up to 2 bar (including safety coefficient)
- Normal flammability

The product fulfils the requirements specified in the assessment principles.
This certificate is only valid for the test results stated in the above-named test reports of the examined
AquaproofX® 1 joint sealant manufactured by StekoX GmbH.

Leipzig, 2 October 2009

Prof. Dr.-Ing. Frank Dehn
Managing director



Dr.-Ing. Ute Hornig
Head of the testing, monitoring and certification body
(PÜZ-Stelle) in compliance with the BRL (German
Building Standards List)