MFPA Leipzig GmbH

Anerkannte Prüfstelle für Baustoffe, Bauteile und Bauarten

PÜZ-Stelle nach Landesbauordnung (SAC 02), Bauproduktengesetz (NB 0800)



CERTIFICATE

Z 5.1 / 09 - 075 - 2

FlexproofX 1

single component SMP-based pourable plastic for external sealing of construction joints in concrete structures with high water penetration resistance

Manufacturer: StekoX GmbH Abdichtungstechnik

Markgröninger Strasse 55/1

71701 Schwieberdingen, Germany

Based on: Test reports no.:

P 2.2 / 07 - 160 of 23 July 2008 P 5.1 / 08 - 218 of 30 July 2008 by MFPA Leipzig GmbH

- Recorded performance characteristics: Adhesive tensile strength on varying substrates
 - Stability
 - · Crack bridging capability
 - · Impermeability on the surface and at joints with a joint width of up to 1 mm at a water pressure of up to
 - · Alkali resistance
 - Normal flammability
 - Durability when subject to water accumulation

The product fulfils the requirements specified in the assessment principles. This certificate is only valid for the test results stated in the above-named test reports of the examined FlexproofX® 1 surface and joint sealing system manufactured by StekoX GmbH.

Leipzig, 24 March 2009

Prof. Dr.-Ing. Frank Dehn Managing director/

Leipzig GmbH

Dr.-Ing. Ute Hornig

Head of the testing, monitoring and certification body (PÜZ-Stelle) in compliance with the BRL (German

Building Standards List)