



1. Reinforcement Murfor RND/Z-150 (100, 50) (min. 3 last brick rows)
2. Wall tie WB(WK) with fixer (3 pc. to every 1 meter)
3. Bracket GSP
4. Wall tie WB(WK) with fixer 5.5 pc./m<sup>2</sup>
5. Reinforcement Murfor RND/Z-50 (above and below the masonry which is not tied)
6. Facing brickwork 85-120 mm
7. Concrete C 20/25
8. Anchor (see notes)
9. Brick or reinforced concrete wall

**NOTES:**

1. Anchor pitch and diameter is selected by calculation. Anchored below the floor slab;
2. Wall heat transfer coefficients according to STR 2.01.03:2009 requirements.